

TESTING **CNAS L0095**

Page 1 of 22 Pages

No.: WTS2017-6980

TEST REPORT

NAME OF SAMPLE: Adaptor with female thread and male bush

CLIENT: Univolt Extrusions (Dongguan) Ltd.

CLASSIFICATION OF TEST: Commission test



TEST REPORT

No.: WTS2017-6980	Page 2 of 22 pages
Name of product:	Trade mark:
Adaptor with female thread and male bush	UNIVOLT
Type/Model : Adaptor with female thread: AFT 20; AFT 25; AFT 32; Male bush: MBS 20; MBS 25; MBS 32	Sample status: –
Manufacturer:	Commissioned by:
Univolt Extrusions (Dongguan) Ltd.	Univolt Extrusions (Dongguan) Ltd.
Manufacturer address:	Commissioner address:
Dongshan Yongfa Industrial Area, Qi Shi Town	Dongshan Yongfa Industrial Area, Qi Shi Town
Dongguan City, Prov. Guangdong, China	Dongguan City, Prov. Guangdong, China
Quantity of sample:	Sampled by:
21 pcs	—
Sample identification:	Sampling at (place):
1#~21#	—
Means of receiving:	Means of sampling:
Submitted by the client	—
Classification of test: Commission test	Sampling date:
Receiving date:	Completing date:
2017.05.18	2017.07.21
Tested according to: IEC 61386-1: 2008 IEC 61386-21: 2002	Test item: Full safety items
Approved by: Liu Bo Reviewed by:	Lü Guowei Tested by: Hong Zhijing
Saak	Aii Georgi Hung 24i jig

Test item particulars:	Fest item particulars: (fittings)					
Conduit system classification (according to Annex A)	on coding:					
Type of conduit			Metallic Non-metallic Composite			
Type of conduit	:	🗌 Pla	in 🗌 Corr	ugated		
Type of conduit fitting	:	🗌 Ме	tallic 🛛 No	n-metallic	Compos	ite
Conduit fitting –quantity		6				
Conduit fitting –type(s)		Adaptor with female thread: AFT 20; AFT 25; AFT 32; Male bush: MBS 20; MBS 25; MBS 32				
Conduit fitting –colour(s)		White				
Method for connection	:	🗌 Thr	readable 🖾No	n-threadal	ble (connecti	on with conduit)
Resistance to compression	······	🗌 Li	ght 🗌 Mediu	m 🗌 Hea	avy 🗌 Ver	y heavy
Resistance to impact	:	🗌 Li	ght 🗌 Mediu	m 🗌 Hea	avy 🗌 Ver	y heavy
Lower / Upper temperature	range	-5/60 ℃				
Resistance to bending		N/A				
Electrical characteristics	······	□With	electrical cont	inuity 🖂	With electrica	al insulating
Resistance to external influ	ences	N/A (only for fittings)				
Resistance against corrosio	on:	: Without protection U With protection: High protection inside and outside				
Tensile strength	ensile strength Heavy Dery heavy			eavy		
Resistance to flame propag	pation	No	n-flame propag	ating 🔲	Flame propa	gating
Suspended load capacity	:	-	ht 🗌 Medium ne declared	🗌 Heav	y 🗌 Very h	eavy
Copy of marking plate: Adaptor with female thread AFT 32 + male bush MBS 32 for example:				UVOLT)		
 Summary of test results: 1. This report is applicable to Adaptor with female thread AFT 20; AFT 25; AFT 32; Male bush MBS 21 MBS 25; MBS 32. 2. Component list table: 				e bush MBS 20;		
Object/ part no.	Manufacturer/trade	mark	Material	Type/ model	Technical data	Standard /approval
Female thread	Univolt Extrusions (Dongguan) Ltd.		PVC	—		_
Male bush	Univolt Extrusions (Dongguan) Ltd.		PVC	—	_	_

Page 4 of 22 pages

No.: WTS2017-6980

IEC 61386-21

Result

7	MARKING AND DOCUMENTATION	Р
7.1	Conduit (conduit fitting) is marked on the product with a trade mark or a name identifying the manufacturer or responsible vendor	Р
	Conduit (conduit fitting) is marked in addition in such a way that it can be identified in the manufacturer's, or responsible vendor's, literature	Р
7.1.1	Conduit is also marked with the classification code, in accordance with annex A, and includes at least the first four digits (optional):	N/A
7.1.2	Manufacturer indicates the compatibility of parts within a conduit system	N/A
7.1.101	Conduit is marked in accordance with 7.1 along its entire length at regular intervals of preferably 1 m but not longer than 3 m (m):	N/A
	Each length is marked at least once	N/A
7.1.102	Minimum inside diameter and the classification for the system in accordance with clause 6 are documented by the manufacturer	N/A
7.2	Conduit fitting is marked in accordance with 7.1, on	Р
	- the product	Р
	- a label attached to the product, or on the box or carton containing the fittings (if the marking on the product is impractical)	Р
7.3	Flame propagating material is orange in colour	N/A
	Flame propagating material is not coloured orange by painting or other superficial means	N/A
	Non-flame propagating material is of any colour except yellow, orange or red, unless is clearly marked on the product to be of non-flame propagating material	P
7.4	Earthing facilities are indicated by the symbol for protective earth in accordance with IEC 60417, symbol 60417-IEC-5019-a	N/A
	This marking is not placed on easily removable parts, for example screws	N/A
7.5	Compliance with 7.1 to 7.4 checked by inspection	Р
7.6	Marking is durable and clearly legible	Р
	Compliance checked by inspection and by rubbing the marking by hand for 15 s with a piece of cloth soaked with water, and again for 15 s with a piece of cloth soaked with petroleum spirit	Р
8	DIMENSIONS	Р

Page 5 of 22 pages

No.: WTS2017-6980

CI.	Requirement – Test	Result	Verdict

8.1	Outside diameters comply with IEC 60423:	See appended table 8.1A	N/A
	Threads comply with IEC 60423:	See appended table 8.1B	N/A
8.2	Threadable conduits and threadable conduit fittings comply with table 101 (except terminating conduit fittings)		N/A
	Non-threadable conduit fittings comply with table 102 (except fittings which are part of a conduit system declaring tensile strength):		Р
	Minimum inside diameter of the conduit system is as declared by the manufacturer	See appended table 8.2C	N/A

9	CONSTRUCTION		Р
9.1	There are no sharp edges, burrs or surface projections within the conduit system		Р
	The manufacturer provides guidelines to assist the safe installation of the conduit system		Р
9.2	Screws, if any, used for attaching components or covers to conduit fittings, or in joints to conduits, do not cause damage to cable insulation when correctly inserted		N/A
	Screws have ISO metric threads		N/A
	Thread-cutting screws are not used		N/A
	Fixing screws and small clips for use with non-metallic or composite conduit fittings, of non-metallic material, are isolated from insulated conductors or cables		N/A
9.3	Test for screw fixing using preformed threads	See appended table 9.3	N/A
	After the test: no damage sustained by the screw or nut, such as breakage of the screw or damage to the head or thread		N/A
9.4	Test for screw fixing using thread-forming screws	See appended table 9.4	N/A
	After the test: no damage, such as breakage of the screw or damage to the head or thread		N/A
9.5	Any material within the joint have at least the same level of resistance to the external influence as either the conduit or the conduit fitting:		N/A
9.6	Indications whether the conduit system that are assembled by means other than threads can be disassembled and if so, how this can be achieved, are provided by the manufacturer		N/A
10	MECHANICAL PROPERTIES		Р

	IEC 61386-21		
CI.	Requirement – Test	Result	Verdict
10.1	Mechanical strength		Р
10.1.1	Conduit systems have adequate mechanical strength		Р
10.1.2	Conduits do not crack and are not deformed when bent or compressed, or exposed to impact or extreme temperature, according to their classification		N/A
10.1.3	Conduit systems intended as a mounting for other equipment have adequate mechanical strength		N/A
10.1.4	Compliance of 10.1.1 to 10.1.3 checked by the tests specified in 10.2 to 10.8		Р
10.2	Compression test	I	N/A
	3 samples of conduit, each (200 ± 5) mm long, subjected to a compression test at (23 ± 2) °C, using the apparatus shown in figure 1	See appended table 10.2	N/A
10.3	Impact test		Р
	12 samples of conduit, each (200 ± 5) mm in length, or 12 samples of conduit fittings subjected to an impact test using the apparatus shown in figure 2	See appended table 10.3	Р
10.3.3	At least 9 of the 12 samples passed the test		Р
10.4	Bending test		N/A
	Conduits declared by the manufacturer as being bendable tested in accordance with 10.4.101, 10.4.102 or 10.4.103		N/A
10.4.101	Metallic conduits		N/A
	Conduit sizes 16, 20 and 25, having a length equal to 30 times the nominal diameter, subjected to a bending test using the apparatus shown in figure 101	See appended table 10.4.101	N/A
	Other sizes tested in accordance with the manufacturer's instructions		N/A
10.4.102	Non-metallic conduits		N/A
	Conduit sizes 16, 20 and 25, having a length of approximately 500 mm, subjected to a bending test using the apparatus shown in figure 103		N/A
	Other sizes tested in accordance with the manufacturer's instructions		N/A
10.4.103	Composite conduits		N/A
	Composite conduits declared by the manufacturer as being bendable tested both in accordance with 10.4.101 and 10.4.102, using new samples for each test	See appended tables 10.4.101 and 10.4.102	N/A
	Other sizes tested in accordance with the manufacturer's instructions		N/A

manufacturer's instructions

Page 7 of 22 pages	No.: WTS2017-6980
IEC 61386-21	

CI.	R

Requirement – Test

Result

Verdict

10.5	Flexing test	N/A
	Sub-clause of part 1 not applicable	_
10.6	Collapse test	N/A
10.6.101	Metallic conduits	N/A
	Metallic conduits not subjected to a collapse test	N/A
10.6.102	Non-metallic and composite conduits	N/A
10.6.102.1	Conduits declared by the manufacturer as being bendable tested in accordance with 10.4.102 with the exception of 10.4.102.3	N/A
	Conduit sizes 16, 20 and 25, having a length of approximately 500 mm, subjected to a bending test using the apparatus shown in figure 103 See appended table 10.6.102	N/A
	Other sizes tested in accordance with the manufacturer's instructions	N/A
10.6.102.2	Samples tested after fixing to a rigid support by means of four straps as shown in figure 104 See appended table 10.6.102	N/A
10.7	Tensile test	N/A
	Conduit systems declaring tensile strength: test carried out on an assembly prepared in accordance with the manufacturer's instructions so that the overall length is approximately 200 mm See appended table 10.7	N/A
10.8	Suspended load test	N/A
	Conduit fitting declared by the manufacturer to be suitable for suspended loads: test carried out with a load suspended by the means provided and installed in accordance with the manufacturer's instructions for a time duration given in table 7	N/A

11	ELECTRICAL PROPERTIES	Р
11.1	Electrical requirements	Р
11.1.1	Conduit systems declaring electrical continuity characteristics are checked by the tests in 11.2 immediately after the tests in 14.2	N/A
11.1.2	Conduit systems of metal or composite materials are so constructed that accessible metal parts can be bonded to earth	N/A
11.1.3	Accessible conductive parts of the metal or composite conduit system, which may become live in the event of a fault, are be effectively earthed	N/A

Page 8 of 22 pages

No.: WTS2017-6980

	IEC 01380-21		
CI.	Requirement – Test	Result	Verdict
11.1.4	Conduit systems of non-metallic or composite materials, where declared, have an adequate electrical insulating strength and insulating resistance		Р
11.2	Bonding test		N/A
	Test carried out on an arrangement of conduits and conduit fittings prepared in accordance with the manufacturer's instructions and figure 3: resistance not exceed 0,1 Ω		N/A
11.3	Electrical insulating strength and resistance		Р
11.3.1	Conduits		N/A
	3 samples of conduit tested in a salt water solution at (23 ± 2) °C, in accordance with figure 4, and submitted after 24 h ± 15 min to a voltage of 2000 V maintained for a period of 15 min +5/0 s: trip device incorporated into the circuit not trip during the test		N/A
	Same samples then subjected to an electrical insulation resistance test with a direct voltage of 500 V applied for (60 ± 2) s: measured insulation resistance greater than 100 M Ω	See appended table 11.3.1	N/A
11.3.2	Conduit fittings		Р
	3 samples of conduit fittings immersed for 24 h \pm 15 min in water at (23 \pm 2) °C and then submitted by means of lead spheres to a voltage of 2000 V maintained for a period of 15 min +5/0 s: trip device incorporated into the circuit not trip during the test		Р
	Same samples then subjected to an electrical insulation resistance test with a direct voltage of 500 V applied for (60 ± 2) s: measured insulation resistance greater than 100 M Ω	See appended table 11.3.2	Р

12	THERMAL PROPERTIES		N/A
12.1	Non-metallic and composite conduits have adequate resistance to heat		N/A
12.2	Samples of conduit, each (100 ± 5) mm long, together with the test apparatus as shown in figure 8, kept for 4 h \pm 5 min in a heating cabinet at the declared temperature given in table 2, with a tolerance of ± 2 °C		N/A
	Each sample then loaded for 24 h \pm 15 min in the apparatus of figure 8 with a total mass as shown in table 9		N/A
12.3	It is possible to pass the appropriate gauge of figure 102 immediately after the removal of the load	See appended table 12	N/A

No.:	WTS2017-6980
------	--------------

IEC 61386-21

Page 9 of 22 pages

Cl. Req

Requirement – Test

Result

Verdict

13	FIRE HAZARD			
13.1	Reaction to fire		Р	
13.1.1	Initiation of fire (not applicable)			
13.1.2	Contribution to fire (under consideration)			
13.1.3	Spread of fire		Р	
	Non-flame propagating conduit systems have adequate resistance to flame propagation		Р	
13.1.3.1	Non-metallic and composite conduit fittings subjected to glow-wire test of IEC 60695-2-1/1 (IEC 60695-2-11) at 750 °C			
	No visible flame or sustained glowing,	See appended table 13.1.3.1	Р	
	Flames and glowing extinguished within 30 s of the removal of the glow-wire (s):	See appended table 13.1.3.1	N/A	
13.1.3.2	Non-metallic and composite conduits subjected to 1 kW flame of IEC 60695-2-4/1 (IEC 60695-11-2), according to the arrangement of figure 7, applied for the period given in table 11			
	 Sample does not ignite, or 	See appended table 13.1.3.2	N/A	
	 In case of ignition: 		N/A	
	a) Flame extinguishes within 30 s	See appended table 13.1.3.2	N/A	
	b) No ignition of the tissue paper	See appended table 13.1.3.2	N/A	
	c) No evidence of burning or charring within 50 mm of the lower extremity of the upper clamp	See appended table 13.1.3.2	N/A	
13.1.4	Additional reaction to fire characteristics (under consideration)			
13.2	Resistance to fire (not applicable)			

14	EXTERNAL INFLUENCES			
14.1	Degree of protection provided by enclosure			
	Conduit systems, when assembled in accordance with the manufacturer's instructions, have adequate resistance to external influences according to the classification declared by the manufacturer, with a minimum requirement of IP30		N/A	
14.1.1	Degree of protection – Ingress of foreign solid objects	See appended table 14.1.1	N/A	
14.1.2	Degree of protection – Ingress of water	See appended table 14.1.2	N/A	
14.2	Resistance against corrosion			
14.2.1	Resistance to corrosion classification for painted and zinc coated steel and steel composite conduits and conduit fittings (table 10):		—	

Page	10	of 22	pages
i ugo		0. 22	pugoo

CI.	Requirement – Test	Result	Verdict

	For non-ferrous metallic and composite conduit systems, the manufacturer provided information about its protection against corrosion	N/A
14.2.2	Tests for resistance to corrosion for painted and zinc coated steel and steel composite conduits systems	N/A
14.2.2.1	Low protection conduit and conduit fittings inspected for completeness of covering by the protective coating, both inside and outside	N/A
14.2.2.2	Test for medium protection conduit and conduit fittings: after completion of the test, the samples showed no more than two blue coloured spots on each square centimetre of the surface, and no blue spot had a dimension larger than 1,5 mm	N/A
14.2.2.3	Test for high protection conduit and conduit fittings: after the test, the sample showed no precipitation of copper which cannot be scrubbed off in running water, if necessary after immersion for 15 s in a 10% solution of hydrochloric acid in water	N/A

15	ELECTROMAGNETIC COMPATIBILITY	N/A
	Products covered by this standards are, in normal use, passive in respect of electromagnetic influences (emission and immunity)	N/A

Page 11 of 22 pages N				No.: WTS	2017-6980
IEC 61386-21					
CI.	Requirement – Test		Result		Verdict

7.1.102	TABLE: Minimum inside diameter declared by manufacturer for the system			
	Size Minimum inside diameter declared manufacturer for the system (mm		Verdict	
	20		N/A	
	25		N/A	
	32		N/A	
	38		N/A	
	50		N/A	
Suppleme	ntary information:			

8.1A	TABLE: Checking of dimensions of conduits						
Size			mum outside diameter Il type of conduits) Minimum outside diameter (metallic conduits)		Minimum outside diameter (non-metallic conduits)		
Outside diameters (mm)	Metric threads	Gauge fig.2 d _g (mm)	Comply (P-F-N/A)	Gauge fig.3A c (mm)	Comply (P-F-N/A)	Gauge fig.3b d _g (mm)	Comply (P-F-N/A)
20 +0/-0,3	M20	20,04	N/A	19,700	N/A	19,70	N/A
25 +0/-0,4	M25	25,04	N/A	24,600	N/A	24,60	N/A
32 +0/-0,4	M32	32,04	N/A	31,600	N/A	31,60	N/A
40 +0/-0,4	M40	40,04	N/A	39,600	N/A	39,60	N/A
50 +0/-0,5	M50	50,04	N/A	49,500	N/A	49,50	N/A
Supplementa	ary informatior	1:					

8.1B	TABLE: Che	cking of dimensions	s of threads			N/A
S	ize	External threads of o	conduits and fittings	Internal threads of fittings		
Outside diameters	Metric	Go gauge fig. 4 (threaded)	No go gauge fig. 4 (plain)	Go gauge fig. 5 (threaded)	No go ga (pla	
(mm) threads		Comply (P-F-N/A)	Comply (P-F-N/A)	Comply (P-F-N/A)	Comply (P-F-N/A)
20 +0/-0,3	M20					
25 +0/-0,4	M25					
32 +0/-0,4	M32					
40 +0/-0,4	M40					
50 +0/-0,5	M50					
Supplement	ary information	n:				

Page 12 of 22 pages No.: WTS2017-6980					
IEC 61386-21					
Cl.	Requirement – Test	Result	Verdict		

8.2A		LE: Checking of hreadable cond		ns according t	o table 101 (thre	eadable condu	uits N/A
		E	xternal thread		Internal thread		·
Size		Minimum length allowed (mm)	Length measured (mm)	Comply (P-F-N/A)	Minimum length allowed (mm)	Length measured (mm)	Comply (P-F-N/A)
20		14,0			15,0		
25		17,0			18,0		
32		19,0			20,0		
40		19,0			20,0		
50		19,0			20,0		

8.2B	acco	TABLE: Checking of maximum entry diameter and minimum entry length details according to table 102 (non-threadable conduits and non-threadable conduit fittings)								
Size		Maximum entry diameter allowed (mm)	Entry diameter measured (mm)	Comply (P-F-N/A)	Minimum entry length allowed (mm)	Entry length measured (mm)	Comply (P-F-N/A)			
20		20.5	20.14	Р	20.0	N/A	N/A			
25		25.5	25.18	Р	25.0	N/A	N/A			
32		32.6	32.18	Р	30.0	N/A	N/A			
38		—	_	_		_	_			
40		—	_			_	_			
50		—	—				—			
Supplement	ary inf	ormation:								

8.2C	TABL	_E: Checking of minimum inside diame	ter of the conduit system	N/A
Size		Minimum inside diameter of the conduit system declared by manufacturer (mm)	Inside diameter of the conduit system measured (mm)	Comply (P-F-N/A)
20				N/A
25				N/A
32				N/A
38				N/A
50				N/A
Supplement	ary inf	ormation:		

	Page 13 of 22 pages No.: WTS2017-6980					
IEC 61386-21						
CI.	Requirement – Test	Result	Verdict			

9.3	TABLE: Screw test (screw fixing using preformed threads)					
Threaded pa	art identification	Nominal diameter of thread (mm)	Column number of table 3 (I or II)	Applied torque (Nm)	Times (5/10)	Verdict
						N/A
Supplement	ary information:					

9.4	TABLE: Screw test (screw fixing using thread-forming screws)					
Threaded pa	art identification	Nominal diameter of thread (mm)	Column number of table 3 (I or II)	Applied torque (Nm)	Times (5/10)	Verdict
						N/A
Supplement	ary information:					

10.2	TABLE:	TABLE: Compression test							N/A
	Classification (first digit) 2					2/3/4/5			_
Size	N° of sample	Ø _{bt} (mm)	F (N)	Ø _{at1} (mm)	[Ø _{bt} - Ø _{at1} / Ø _{bt}]100 ≤ 25 % (%)	Ø _{at2} (mm)	[Ø _{bt} - Ø _{at2} / Ø _{bt}]100 ≤ 10 % (%)	No visible cracks (P/F)	Verdict
	ntary inform								

F = Compression force, reaching the value shown in table 4 within (30 ± 3) s

 $Ø_{bt}$ = Outside diameter measured before the test

 $Ø_{at1}$ = Outside diameter measured after the force given in table 4 has been applied for (60 ± 2) s where flattening has taken place, without removing the force

Outside diameter measured after the test where flattening has taken place, (60 ± 2) s after removal of Ø_{at2}= the force given in table 4 and the intermediate piece

Page 14 of 22 pages	Page	14 o	f 22 p	bages
---------------------	------	------	--------	-------

CI.	Requirement – Test	Result	Verdict

10.3	TABLE:	TABLE: Impact test						Р
	Classific	ation (second dig	jit)	:	2	-		
	Test tem	nperature (table 1) (°C): -5						_
	Mass of	f hammer (table 5) (kg) 1.0						_
	Fall heig	nt (table 5) (mm) 10						_
0.	N° of		bility to pass the 102 through the aple	-		ntegration / No cracks	Total n° of samples	Vordiot
Size	sample	N° of samples which passed the test	N° of samples which failed the test	N° of sam which pas the test	sed	N° of samples which failed the test	which passed the test	Verdict
	1-12	12	—	12		_	12	Р
Supplemen	tary inform	nation:						

10.4.101	TABLE: Bending test (metallic or composite conduits)							N/A
Size	N° of sample	Length of sample (mm)	Inside bending radius R (mm)	Welded seam, if any (outside of the bend/on the side)	No visible cracks (P/F)	Seam not opened, if any (P/F)	Section not distorted unduly: test with gauge of figure 102 (P/F)	Verdict
16	1							
20	1							
25	1							
Supplementary information:								

10.4.102	TABLE:	TABLE: Bending test (non-metallic or composite conduits)					
	Type of t	pending aid	Coiled	—			
	Classifica	Classification (third digit)					
	Samples conditioned at least 2 h at test temperature (table 1) (°C):					—	
Size	N° of sample	Possibility to remove the bending aid without damage (P/F)	No visible c (P/F)	racks	Possibility to pass the gauge of figure 102 (P/F)	Verdict	
20						N/A	
Supplemer	Supplementary information:						

Page 15 of 22 pages

No.: WTS2017-6980

10.6.102	TABLE:	Collapse test (non-r	netallic and	d composite	e con	duits)	N/A
	Type of I	Type of bending aid					_
	Classification (fourth digit)						_
	Test temperature of the heating cabinet at which the support with the sample in position was kept for 24 h ± 15 min (table 2) (°C)				-		
Size	N° of sample	Possibility to remove the bending aid without damage (P/F)	No visible cracks (P/F)	Possibility pass the ga of figure 1 (P/F)	auge	Possibility to pass the gauge of figure 102 after the heating period of 24 h (P/F)	Verdict
							N/A

10.7	TABLE: T	TABLE: Tensile test					
	Classificat	ion (tenth digit)		:	2/3/4/5	_	
	Increasing tensile force value reached in (30 ± 3) s and then applied for (120 ± 10) s (table 6) (N)					—	
Size	N° of assembly sample	Art./Type Ref. of the conduit fittings assembled to the conduit	Elongation occurred (Y/N)	or termir	After the test the conduit fittings or terminating conduit fittings remained properly assembled (P/F)		Verdict
Supplemer	ntary informa	tion:					

10.8	TABLE: Suspended load test (conduit fittings)							N/A
	Classifica	ation (twelfth digit)			2/3/4	/5		_
	Test temperature of the heating cabinet at which the non-metallic and composite conduit fitting was kept during the test (table 2) (°C)					-		
Size	N° of sample	Art./Type Ref. of the conduit fitting	Load (N)	Duratio	n (h)	No visible cracks (P/F)	No deformation (P/F)	Verdict
	1							
	2							
	3							
Supplemen	itary inform	ation:						

11.2	TABLE: Bonding test		
	Classification (sixth digit)	1/3	—

Page 16 of 22 pages

No.: WTS2017-6980

IEC 61386 21

		IEC 61386-21	
CI.	Requirement – Test	Result	Verdict

Size	N° of arrangement sample	Number and Art./Type Ref. of the conduit fittings coupled together the 10 pieces of conduit	Voltage drop measured (V)	Resistance (Ω)	Verdict			
Supplement	Supplementary information:							

11.3.1	TABLE: E	TABLE: Electrical insulating strength and resistance test (conduits)			
Size	N° of sample	Device incorporated into the circuit not trip during the insulating strength test (P/F)	Insulation resistance measured $(M\Omega)$	Verdict	
				N/A	
Supplement	ary informa	tion:			

11.3.2	TABLE: Electrical insulating strength and resistance test (conduit fittings)							
Size	N° of sample	Art./Type Ref. of the conduit fitting	Device incorporated into the circuit not trip during the insulating strength test (P/F)	Insulation resistance measured (MΩ)	Verdict			
	1	AFT 32 + MBS 32	Р	500	Р			
32mm	2	AFT 32 + MBS 32	Р	500	Р			
	3	AFT 32 + MBS 32	Р	500	Р			
Supplement	Supplementary information:							

Γ

12	TABLE:	Heating test (conduits)		N/A	
	Classific	ation (fourth digit)	:	—	
	Test temperature of the heating cabinet at which the non-metallic and composite conduit fitting was kept for 4 h \pm 5 min (table 2) (°C)				
	Classification (first digit):				
	Total mass applied for 24 h ± 5 min in an apparatus as shown in figure 8 (table 9) (kg)				
Size	N° of sample	Sample after the period of 24 h ± 5 min and then cool to room temperature under load: no visible cracks (P/F)	Possibility to pass the gauge of figure 102 immediately after the removal of the load (P/F)	Verdict	
				N/A	
Supplemen	tary inform	nation:		1	

			Page 17 of 22 page	s No.: WTS	2017-6980
			IEC 61386-21		
CI.	Requirement – Test			Result	Verdict
	Material	designation	:	PVC	—
	Test tem	perature (°C)	:	750	—
Size	N° of sample	Art./Type Ref. of the conduit fitting	Visible flame or sustained glowing (Y/N)	Time of extinguishment of flames and glowing, if any, after removal of the glow-wire (s)	Verdict
	1	AFT 32 + MBS 32	Ν		Р
20mm	2	AFT 32 + MBS 32	Ν	_	Р
	3	AFT 32 + MBS 32	Ν	_	Р
Supplemen	tary inform	ation:			

Page 18 of 22 pages

No.: WTS2017-6980

IEC 61386-21

CI.	Requirement – Test	Result	Verdict			

13.1.3.2	TABLE: conduits	•	pagation re	sistance	test (r	non-meta	allic and	composite	N/A
	Material	designation							—
Size	N° of sample	Highest mean material thickness (mm)	Flame application time (+1/0) (s)	Sample did not ignite (P/F)	extingui of flam glowing after rer	ie of ishment ning or g, if any, moval of flame (s)	No ignition of the tissue paper (P/F)	No evidence of burning or charring (P/F)	Verdict
									N/A

14.1.1	TABLE: Verification of protection against ingress of solid objects				
		ion - Protection agair eventh digit)			-
	For IP5X, category 2 applied			-	-
Size	N° of assembly sample	Art./Type Ref. of the conduit fitting with a short length of conduit assembled in each conduit entry	Assembly tested in accordance with the appropriate test of IEC 60529 (P/F)	No ingress of dust visible to normal or corrected vision without magnification in the assembly tested for IP5X or IP6X (P/F/NA)	Verdict
					N/A
Supplemen	itary informa	tion:			1

N/A

Page 19 of 22 pages

ANNEX 1 PHOTOGRAPH Adaptor with female thread AFT 20



Adaptor with female thread AFT 25



Page 20 of 22 pages


ANNEX 1 PHOTOGRAPH Adaptor with female thread AFT 32



Male bush MBS 20



Page 21 of 22 pages ANNEX 1 PHOTOGRAPH Male bush MBS 25



Important

- 1. The test report is invalid without the official stamp of CVC;
- 2. Any photocopies or part photocopies of the test report are forbidden without the written permission from CVC;
- The test report is invalid without the signatures of Approval and Reviewer;
- 4. The test report is invalid if altered;
- 5. Objections to the test report must be submitted to CVC within 15 days;
- 6. Generally, commission test is responsible for the tested samples only;
- 7. "P" means "pass", "F" means "fail", "N/A" means "not applicable" and
 - " / "means "not test".

Address: No.3,Tiantaiyi Road, Kaitai Avenue, Science City, Guangzhou, China Tel: 020 32293888 Fax: 020 32293889 Post Code: 510663 E-mail: <u>office@cvc.org.cn</u> http://www.cvc.org.cn